

This authorizes the application of the Certification Mark(s) shown below to the models described in the Product(s) Covered section when made in accordance with the conditions set forth in the Certification Agreement and Listing Report. This authorization also applies to multiple listee model(s) identified on the correlation page of the Listing Report.

This document is the property of Intertek Testing Services and is not transferable. The certification mark(s) may be applied only at the location of the Party Authorized To Apply Mark.

Applicant:	AW Sheepscot Holding Company	Manufacturer:	AW Sheepscot Holding Company
Address:	2440 W. Corporate Preserve Drive, Suite 600,Oak Creek, WI 53154	Address:	2440 W. Corporate Preserve Drive, Suite 600,Oak Creek, WI 53154
Country:	USA	Country:	USA
Contact:	Chris Husson	Contact:	Chris Husson
Phone:	(414)574-4300	Phone:	(414)574-4300
FAX:	--	FAX:	--
Email:	chusson@aw-lake.com	Email:	chusson@aw-lake.com

Party Authorized To Apply Mark: Same as Manufacturer
Report Issuing Office: Cortland, New York

Control Number: 5010080 **Authorized by:** 
for Dean Davidson, Certification Manager



This document supersedes all previous Authorizations to Mark for the noted Report Number.

This Authorization to Mark is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Authorization to Mark. Only the Client is authorized to permit copying or distribution of this Authorization to Mark and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement and in this Authorization to Mark. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.

Intertek Testing Services NA Inc.
545 East Algonquin Road, Arlington Heights, IL 60005
Telephone 800-345-3851 or 847-439-5667 Fax 312-283-1672

Standard(s):	ISA 12.12.01:2016 Ed.7 Nonincendive Electrical Equipment For Use In Class I And II, Division 2 And Class III, Divisions 1 And 2 Hazardous (Classified) Locations. CSA C22.2#213:2016Ed.2 Nonincendive Electrical Equipment For Use In Class 1 And 2, Division 2 And Class 3, Divisions 1 And 2 Hazardous(Classified) Locations
Product:	Coriolis Mass Flow Meters For Use in Classified Hazardous Location Class I Division 2 Group ABCD T4 Ambient Temperature: -40°C to +70°C
Brand Name:	AW Lake Company
Models:	TCE-6001-FSDD-EX2-XX TCE-6011-FSDD-EX2-XX (To be used with flowmeter)