

IECEx Certificate of Conformity

Page 1 of 3

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.:	IECEx SIR 18.0072X	Issue No: 0	Certificate history
------------------	--------------------	-------------	---------------------

Issue No. 0 (2019-07-12)

Status: Current

Date of Issue: 2019-07-12

Applicant: KEM Küeppers Elektromechanik GmbH

Liebigstraße 5 Karlsfeld 85757 **Germany**

Equipment: <TRICOR Coriolis Flow Meter>

Optional accessory:

Type of Protection: Flameproof and Intrinsically Safe

Marking:

Refer to the Certificate Annexe

Approved for issue on behalf of the IECEx N Jones

Certification Body:

Position: Certification Manager

Signature:

(for printed version)

Date:

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

SIRA Certification Service CSA Group Unit 6, Hawarden Industrial Park Hawarden, Deeside, CH5 3US United Kingdom







IECEx Certificate of Conformity

Certificate No: IECEx SIR 18.0072X Issue No: 0

Date of Issue: 2019-07-12 Page 2 of 3

Manufacturer: KEM Küeppers Elektromechanik GmbH

Wettzellerstraße 22 93444 Kötzting **Germany**

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Explosive atmospheres - Part 0: General requirements

Edition:6.0

IEC 60079-1: 2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

Edition:7.0

IEC 60079-11: 2011 Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Edition:6.0

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the

Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

GB/SIR/ExTR19.0184/00 GB/SIR/ExTR19.0185/00

Quality Assessment Report:

DE/TPS/QAR12.0003/06



IECEx Certificate of Conformity

Certificate No:	IECEx SIR 18.0072X	Issue No: 0

Date of Issue: 2019-07-12 Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The Tricor Coriolis Mass Flow Meters (TCM) are intended to measure simultaneously mass flow, volume flow, temperature and density. The equipment is separated into two distinct parts; an intrinsically safe stainless steel process meter (TCM) and a flameproof transmitter (TCE).

In the Compact version of the TCM, the flameproof TCE transmitter is mounted directly to the intrinsically safe TCM meter. This is the most convenient configuration of the equipment, but the permitted process temperature range is lower due to radiated heat from the process into the TCE transmitter.

In the Wall Mounted version of the TCM, the flameproof TCE transmitter is separated from the intrinsically safe TCM meter by a cable. The cable length can be varied in set lengths to suit individual requirements, but is at least 3m long. Mounting the flameproof TCE transmitter away from the intrinsically safe TCM meter means that the TCE transmitter does not experience heating or cooling effects from the process material, allowing for a greater process temperature range.

Refer to the Annexe for Model codes and entity parameters

SPECIFIC CONDITIONS OF USE: YES as shown below:

- 1. The temperature of the TCE can reach 82°C at the cable entry and the branching point in a 70°C ambient, or with a process temperature of 70°C in compact models of the equipment. This shall be considered when selecting field wiring and cable entry devices
- 2. The equipment contains a shunt zener diode interface, which requires connection to a suitable earth in accordance with IEC 60079-14.
- 3. Remote terminal boxes of the equipment may be manufactured from aluminium; in the event of rare incidents, ignition sources due to impact and friction sparks could occur. This shall be considered when the remote version of the TRICOR flow meters are being installed in locations that specifically require group II Zone 0 applications.
- 4. The TCM transducer cable shall not exceed 30 meters when it is not provided by the manufacturer. The cable shall be either Type A or Type B cable as defined in IEC 60079-14 and the conductors inside of the cable shall provide an insulation of 0.25 mm thick minimum.
- 5. The installer shall ensure that the maximum ambient temperature of the equipment when installed is not exceeded.
- 6. Process temperature range for remote versions of the equipment is determined as follows:

-40°C \leq Tp \leq +70°C (for T4)

-40°C \leq Tp \leq +135°C (for T3)

-60°C ≤ Tp ≤ +200°C (for T2)

Annex

IECEx SIR 18.0072X Annexe Issue 0.pdf

Annexe to: IECEx SIR 18.0072X Issue 0

Applicant: KEM Küppers Elektromechanik GmbH





Marking

Apparatus:

TCE 8***	TCM *****
II 2G	II 2G
Ex db ia IIC* T4 Gb	Ex db ia IIC** T4 Gb
Ex db ia IIB* T4 Gb	Ex db ia IIB** T4 Gb
Remote Mount Version	Remote Mount Version
II 2(1)G	II 1G
Ex db [ia Ga] IIC T4 Gb	Ex ia IIB** T4T2 Ga
	Ex ia IIC** T4T2 Ga
-40°C ≤ Ta ≤ +70°C	-40°C ≤ Ta ≤ +70°C
-40°C ≤ Tprocess ≤ +70°C ***	-40°C ≤ Tprocess ≤ +70°C (for T4)
	-40°C ≤ Tprocess ≤ +135°C (for T3) - remote version only
	-60°C ≤ Tprocess ≤ +200°C (for T2) - remote version only

TCE 8***

- * IIC when paired with TCM*0325, TCM*0450, TCM*0650, TCM*1550, TCM*3100, TCM*5500 and TCM*7900
 - IIB when paired with TCM*028K, TCM*065K
- *** Only applicable to Compact versions of the TCM, where the TCE transmitter is directly mounted to the TCM process meter.

TCM ****

** - IIC for TCM*0050, TCM*0100, TCM*0325, TCM*0450, TCM*0650, TCM*1550, TCM*3100, TCM*5500 and TCM*7900
IIB for TCM*028K, TCM*065K, TCM*230K, TCM*430K

Note - TCM*0050, TCM*0100, TCM*230K, TCM*430K are only available in remote versions

Model Code Structure

TCE	-	Χ	XXXX	1	X	-	XXXX	-	XX	-	XX
		Unused	Enclosure &		Mounting		Interface		Hazardous		Customer
			Electronics		Options		Options		Location		Options
									Rating		

Product Code Reference	Ref	Description	
Enclosure & Electronics	80XX	Aluminium enclosure	
	81XX	Stainless steel 316 enclosure	
Mounting Options	W/I	Remote (wall mount)	
	C/K/M/O	Compact (meter mount)	
Interface Options X ¹ X ² X ³ X ⁴			
X ¹ - Interface	S/A/D/E/Z	Interface bus	
X ² – Supply voltage	D	24V DC	
	M	Mains 100-240V AC	
X ³ – Transmitter Options	S/C/A	Electronics options such as pressure compensation	
X ⁴ – Cable length	S/B/C/D/E/F/G/H/I/J/O/P/Q/N	3 ≤ Meters ≤ 30	
Hazardous Location Rating	Ex	ATEX + IECEx Zone1: Group IIC or IIB, T4	
Customer Specific	-	Customer specific modifications not relevant to certification	

Date: 12 July 2019 Page 1 of 3

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900
Email: ukinfo@csagroup.org
Web: www.csagroupuk.org

Annexe to: IECEx SIR 18.0072X Issue 0

Applicant: KEM Küppers Elektromechanik GmbH



Apparatus: <TRICOR Coriolis Flow Meter>

TCE 8*** entity parameters

Input	Um = 250 Vac			
Output	Entity parameters			
Oscillator/Driver coil (Linear)	TCE 8*0n (low power)	Uo = 8.27 V, Io = 0.2 A, Po = 0.4135 W, Co = 7.2 μ F, Lo = 0.84 mH		
(Linear)	TCE 8*1n (high	Uo = 15.34 V, Io = 0.37 A, Po = 1.42 W, Co = 0.521		
	power)	μF, Lo = 0.21 mH		
Signal pick-up coil (Linear)	Uo = 2 V, Io = 0.02 A, Po = 0.01 W, Co = 100 μF, Lo = 88.84 mH			
Temperature sensor (Trapezoidal)	Uo = 5 V, Io = 0.045 A, Po = 0.4132 W, Co = 100 μF, Lo = 17.51 mH			

TCM	Χ	XXXX	XX	XXXX	XXXX	XX	XX
	Meter	Max Flow	Process	Mechanical	Electronics	Ex Rating	Customer
	Series	Rate	Connections	Options	Options		Options

Version	Process temperature
Compact	-40 °C ≤ Tprocess ≤ +70 °C (for T4)
Remote	-40 °C ≤ Tprocess ≤ +70 °C (for T4)
	-40 °C ≤ Tprocess ≤ +135 °C (for T3)
	-60 °C ≤ Tprocess ≤ +200 °C (for T2)

Transducer Type TCM***** has the following type codes (first * - blank or a letter which is not related to Exrelevant parameters)

Type	Flow rate	Entity parameters					
		Oscillator/Driver coil	Signal pick-up coil	Temperature sensor	Group		
		(Linear)	(Linear)	(Trapezoidal)			
TCM*0050	≤ 50 kg/h	Ui = 8.27 V,	Ui = 2 V,	Ui = 5 V,	IIC		
		Ii = 0.2 A,	Ii = 0.02 A,	Ii = 0.045 A,			
TCM*0100	≤ 100 kg/h	Pi = 0.4135 W,	Pi = 0.01 W,	Pi = 0.4132 W,			
1011 0100	_ ≥ 100 kg/11	Ci = 0 F,	$Ci = 0 \mu F$,	Ci = 0 F,			
		Li = 5.25 mH	Li = 5.25 mH	Li = 0 H			
TCM*0325	≤ 325 kg/h	Ui = 8.27 V,	Ui = 2 V,		IIC		
TCM*0450	≤ 450 kg/h	Ii = 0.2 A,	Ii = 0.02 A,		IIC		
TCM*0650	≤ 650 kg/h	Pi = 0.4135 W,	Pi = 0.01 W,		IIC		
TCM*1550	≤ 1,550 kg/h	Ci = 0 F,	Ci = 0 F,		IIC		
TCM*3100	≤ 3,100 kg/h	Li = 1.94 mH	Li = 1.94 mH		IIC		
TCM*5500	≤ 5,500 kg/h				IIC		
TCM*7900	≤ 7,900 kg/h				IIC		
TCM*028K	≤ 28,000 kg/h	Ui = 15.34 V,			IIB		
TCM*065K	≤ 65,000 kg/h	Ii = 0.37 A,			IIB		
		Pi = 1.42 W,					
		Ci = 0 F,					
		Li = 7.875 mH					
TCM*230K	≤ 230,000	Ui = 15.34 V,			IIB		
	kg/h	Ii = 0.37 A,					
TCM*430K	≤ 430,000	Pi = 1.42 W,			IIB		
	kg/h	Ci = 0 F,					
		Li = 13.65 mH					
The type na	The type name is further classified by letters or numbers not affecting Ex-relevant parameters						

Date: 12 July 2019 Page 2 of 3

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900
Email: <u>ukinfo@csagroup.org</u>
Web: <u>www.csagroupuk.org</u>

Annexe to: IECEx SIR 18.0072X Issue 0

Applicant: KEM Küppers Elektromechanik GmbH





Conditions of Manufacture

i. To avoid potential confusion, compact models of the TCE transmitter paired with a model of the TCM rated for Group IIB only, shall be marked Ex db ia IIB T4 Gb.

- ii. The manufacturer shall apply a suitable thread locking compound to the threads of Bartec type 07-91 and Quintex type LB line bushings when used.
- iii. The manufacturer shall remove any Limatherm applied external labels from component enclosures Limatherm XD-ID100, XD-ID100win, XD-SID100 & XD-SID100win.
- iv. The manufacturer shall supply a copy of the user instruction manual and certificates with each production unit of the equipment.
- v. For remote versions of the TCE 8XXX that feature a factory installed cable gland for the intrinsically safe interface cable between the TCE and the TCM; the factory installed gland shall be a suitably equipment certified barrier gland to the requirements of IECEx, be suitable for the ambient temperature range of the equipment and be suitable for the type of cable that is installed within it.
- vi. The products covered by this certificate incorporate the following previously certified devices; it is therefore the responsibility of the manufacturer to continually monitor the status of the certification associated with these devices, and the manufacturer shall inform CSA UK of any modifications of the devices that may impinge upon the explosion safety design of their products.

Description	Certificate Number
Limatherm XD-ID100 & XD-ID100win enclosure	IECEx FTZU 10.0019U
Limatherm XD-SID100 & XD-SID100win enclosure	IECEx FTZU 15.0037U
Bartec type 07-91 line bushing	IECEx EPS 13.0045U
Quintex type LB line bushing	IECEx EPS 11.0004X

Date: 12 July 2019 Page 3 of 3

Sira Certification Service

Unit 6 Hawarden Industrial Park, Hawarden, CH5 3US, United Kingdom

Tel: +44 (0) 1244 670900 Email: <u>ukinfo@csagroup.org</u> Web: www.csagroupuk.org